



Chief Safety Officer Decision
(Application for Substitution, Equivalency, or Exemption)

Date: 2024-May-17 | 12:38:23 PM NDT

C-NLOPB Reference: 2024-RQ-0030

Applicant: Stena Drilling Ltd.

Applicant Reference: DMX-RQ-24-029 Rev 1

Installation Name: MV-Stena DrillMAX


Authority: *Canada-Newfoundland and Labrador Atlantic Accord Implementation Act, subsection 151(1) & section 205.069*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1) and section 201.66

Regulation: *Subsection 28(9)(10) of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer approves the Applicant's, the owner of the Stena *DrillMAX*, use of area audible and visual alarms, alarms and notifications at the fire and gas indicator panel in the control station, system manual activation and procedural controls to mitigate the potential for personnel entering a space or remaining in a space when a fixed fire fighting system has been activated, in lieu of the requirements in Subsection 9 and 10 of the *Newfoundland Offshore Petroleum Installations Regulations*.

DocuSigned by:

94C2434A59B546B...

Chief Safety Officer

Cc: Matthew Williams (DNV)