



Chief Safety Officer Decision
(Application for Substitution, Equivalency, or Exemption)

Date: 2024-May-16 | 2:56:37 PM NDT

C-NLOPB Reference: 2024-RQ-0043

Applicant: Stena Drilling Ltd.

Applicant Reference: DMX-RQ-24-023 Rev 1

Installation Name: *MV-Stena DrillMAX*

Authority: *Canada-Newfoundland and Labrador Atlantic Accord Implementation Act, subsection 151(1) & section 205.069*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1) and section 201.66

Regulation: Subsection 25(4) of the *Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer approves the Applicant's, the owner of the *MV-Stena DrillMAX*, use of deluge systems activation and alarm arrangements which are in compliance with *DNV Offshore Standard DNV-OS-D301 'Fire Protection'* in lieu of the requirements in Subsection 25(4) of the *Newfoundland Offshore Petroleum Installations Regulations*.

DocuSigned by:

A handwritten signature in black ink, appearing to read "P. Williams", enclosed within a blue DocuSign signature box.

04C2434A69B546B...

Chief Safety Officer

Cc: Matthew Williams (DNV)