



Chief Safety Officer Decision
(Application for Substitution, Equivalency, or Exemption)

Date: 2024-May-13 | 8:25:45 AM NDT

C-NLOPB Reference: 2024-RQ-0047

Applicant: Stena Drilling Ltd.

Applicant Reference: DMX-RQ-24-025 – Rev 1

Installation Name: Stena DrillMAX

Authority: *Canada-Newfoundland and Labrador Atlantic Accord Implementation Act, subsection 151(1) & section 205.069*

Canada-Newfoundland and Labrador Atlantic Accord Implementation Newfoundland and Labrador Act, subsection 146(1) & section 201.66

Regulation: *Subsection 27 of the Newfoundland Offshore Petroleum Installations Regulations*

Decision:

The Chief Safety Officer approves the Applicant's, the owner of the *Stena DrillMAX*, proposal to use IMO Res A.800 (19), the FSS Code. Ch. 8, and to test and inspect in accordance with the applicable requirements of NFPA 25 as referenced by NFPA 13 and NFPA 750 as applicable to the Hi-Fog fire suppression system in the accommodation area in lieu of the requirements of *Newfoundland Offshore Petroleum Installations Regulations, subsection 27.*

DocuSigned by:

94C2434A59B546B...
Chief Safety Officer